

**GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**

From:
The Station Fire Officer,
Fire Station, Sangareddy.

To: ✓
The Secretary,
Nagarjuna BED & DED College,
Kothlapur (V), Sangareddy (M),
Medak District.

Rc.No. 15/SFO/SRD/2015, Dated: 02-01-2016.

Sir,

Sub: - Telangana State Disaster Response & Fire Services Department – Central Region-
Medak District-Fire Station, Sangareddy -Renewal of No Objection Certificate for
Occupancy to Nagarjuna BED & DED College, D. No. 5-25, Sy. No. 55/A1, 56/A1,
56/4, Kothlapur (V), Sangareddy (M), Medak District– Issued

Ref: - 1. Application of the Chairwoman, Nagarjuna Educational Society, Sangareddy.
2. No Objection Certificate Rc.No.2732/A1/2014, Dt.30-12-2014, issued by the
District Fire Officer, Medak District.
3. Joint inspection conducted by the undersigned along with Sri P.Kamalakar,
Leading Fireman of Fire Station, Sangareddy.
4. Circular Memo Rc.No.15009/MSB/CR/HYD/2012, Dt.13-04-2015 of Director General
of Telangana State Disaster Response and Fire Services, Hyderabad

\$ \$ \$ \$ \$ \$

vide reference 1st cited, the Chairwoman, Nagarjuna Educational Society, Sangareddy has
submitted application for issue of Renewal of No Objection Certificate for Occupancy to the Existing
Educational Building of Nagarjuna BED & DED College, D. No. 5-25, Sy. No. 55/A1, 56/A1, 56/4,
Kothlapur (V), Sangareddy (M), Medak District. In this regard it is informed that the No Objection
Certificate for Occupancy to the above College building was issued vide reference 2nd cited.

2. Vide reference 3rd cited, I with the assistance of Sri P.Kamalakar, Leading Fireman of Fire
Station, Sangareddy inspected the above education building on 29-12-2015 and observed that he
management has been maintaining the fire safety systems in good working condition.

3. Particulars of the Educational Building:-
i) Height of the Building: 09.20 Meters.

ii). Floor wise particulars:

Sl. No	Floor	Floor Area in Sq. Meters	Occupancy	No. of students & Staff members in the floor
1.	Ground Floor	1012.82 Sq.Mtrs	Educational	110
2.	First Floor	1012.82 Sq.Mtrs	Educational	80
3	Second Floor	1012.82 Sq.Mtrs	Educational	80
	Total:	3038.46 Sq.Mtrs	--	270

iii) (a) Means of Escape:

SNo	Details of Staircase	Nos.	Provided
1.	Internal Staircases	01 No.	01.10 Mtrs.
2	External Staircases	01 No.	01.10 Mtrs.
	Total:	02 No.s	02.20 Mtrs.

(b) Details of Occupant Load per unit Exit Width in each floor:

Sl No	Floor	Built up Area in Sq Mtrs	No. of Occupants	Means of Escape as per NBC-2005	Provided
1	Ground	1012.82 Sq.Mtrs	110	--	--
2	First Floor	1012.82 Sq.Mtrs	80	01.60 Mtrs	02.20 Mtrs
3	Second Floor	1012.82 Sq.Mtrs	80	01.60 Mtrs	02.20 Mtrs

(Contd.....2p)

iv) (a) Fire Safety Measures:

Sl. No	Fire safety Measures	As per NOC from occupancy	Now Provided	Deficiency
1	Fire Extinguishers	24 No.s	24 No.s	Nil
2	Hose Reel	03 No.s	03 No.s	Nil
3	Terrace Tank	10,000 Ltrs.	10,000 Ltrs.	Nil
4	Booster Pump	450 LPM	450 LPM	Nil

(b) Floor wise fire fighting Installations provided by the management:

Sl. No	Floor	Extinguishers	Hose Reel	Automatic Sprinkler System	Terrace Tank	Fire Pumps
1	Ground	08 No.s	01 No.	NA	NA	NA
2	First Floor	08 No.s	01 No.	NA	NA	NA
3	Second Floor	08 No.s	01 No.	NA	NA	NA
4	Terrace Floor	--	--	--	01 No	01 No
	Total	24 No.s	03 No.s	--	01 No	01 No

4. The above fire fighting systems are randomly checked/tested by me during the inspection and found in good working condition.

5. The Management remitted Rs.10,000/- (Rupees Ten thousand only) vide challan NO.0000011160, Dt.02-01-2016 at State Bank of Hyderabad, Patancheru Br towards User Charges.

5. In view of the above, under the powers delegated in the reference 4th cited and on the basis of the inspection conducted by me, the Renewal of No Objection Certificate for Occupancy is issued to the Existing Educational Building of of Nagarjuna BED & DED College, D. No. 5-25, Sy. No. 55/A1, 56/A1, 56/4, Kothlapur (V), Sangareddy (M), Medak District, subject to the following conditions.

i	All the firefighting equipment shall be maintained in good working condition as seen during inspection.
ii	All the escape / exit routes shall not be kept locked / blocked or encroached.
iii	All the occupants must know the correct method of operation of the fire fighting system installed.
iv	Any loss of life or property due non-functioning of fire safety measures and other installations shall be the responsibility of the management.
v	All Students / Staff members of the institutions shall be trained to operate the fire safety equipments during emergency.
vi	Addition / alteration, if any in the building may be obtained with prior permission from this Department.
vii	Mock drills should be conducted once in 3 months for initial two year. Thereafter, once in every 6 Months.

6. **This Renewal No Objection Certificate for Occupancy is valid up to 29-12 2016 and it should be renewed every year. The Management is requested to submit application for renewal of No Objection Certificate for Occupancy before one month of expiry of the Certificate**

Yours faithfully,


 Station Fire Officer,
 Fire Station, Sangareddy.

Copy submitted to the District Fire Officer, Medak District.
 Copy submitted to the Asst. District Fire Officer, Medak District.